

Notification
Energy and Petrochemicals Department,
Sachivalaya, Gandhinagar.

Dated the 1 FEB 2016

No. GU/10/CEI/11-2012/4140/K: In exercise of the powers conferred by sub-regulation (1) of regulation 43 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 as amended up to date and in supersession of this Department's Notification No. GU/87/CEI/11-2012/4140/K, Dated the 10th July, 2012, the Government of Gujarat hereby notifies that on and with effect from the date of publication of this notification in the *Official Gazette*, electrical installation of voltage exceeding 440 Volts shall be inspected by the Electrical Inspector for the purpose of regulation 43 of the aforesaid Regulations before the supply of electricity to such installation is commenced or recommenced.

By order and in the name of the Governor of Gujarat,


(Hitendra Patel)

Under Secretary to Government

Copy to:

- ✓ The Chief Electrical Inspector, Gandhinagar (with 50 spare copies).
- The Dy. Chief Electrical Inspector, Gandhinagar, Rajkot, Vadodara and Mehsana
- The Electrical Inspectors at Ahmedabad, Vadodara, Mehsana, Rajkot, Surat, Bhavnagar, Nadiad, Valsad and Bhuj
- The Assistant Electrical Inspector at Ahmedabad, Gandhinagar, Vadodara, Mehsana, Rajkot, Junagadh, Jamnagar, Bhavnagar, Surendranagar, Palanpur, Himmatnagar, Nadiad, Bharuch, Surat, Navsari and Valsad.
- All District Collectors
- The M. D., M/s. Gujarat Urja Vikas Nigam Ltd., Vadodara
- The M. D., M/s. Madhya Gujarat Vij Co. Ltd.
- The M. D., M/s. Daxin Gujarat Vij Co. Ltd.
- The M. D., M/s. Pashchim Gujarat Vij Co. Ltd.
- The M. D., M/s. Uttar Gujarat Vij Co. Ltd.
- The Secretary, Licensing Board, Gandhinagar
- The Accountant General, Gujarat, Ahmedabad.
- The Additional Accountant General, Rajkot.
- The Manager, Government Central Press, Gandhinagar ... With a request to publish this notification in Government Gazette Par-IV-A of the extraordinary Government Gazette of to-day and send 100 copies to this Department.